



Product Service

Attestation of Conformity

No. N8A 117322 0002 Rev. 00

Holder of Certificate: **Maanshan Kinse Energy Technology Co., LTD**
No.9, Tagang Industrial Park, Tongzha Town,
Hanshan County
243000 Ma'anshan City, Anhui
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062231701-00

Date, 2022-08-31

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 117322 0002 Rev. 00

Model(s): KSxxx-132-M210, xxx=650 to 670 in step of 5,
 KSxxx-120-M210, xxx=590 to 610 in step of 5,
 KSxxx-110-M210, xxx=540 to 560 in step of 5,
 KSxxx-144-M182, xxx=530 to 550 in step of 5,
 KSxxx-132-M182, xxx=485 to 505 in step of 5,
 KSxxx-120-M182, xxx=440 to 460 in step of 5,
 KSxxx-108-M182, xxx=395 to 415 in step of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to: EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06